

# Kitemark™ Certificate

This is to certify that:

VISCORP Sp. z o.o.  
Morawica 355  
Morawica  
32-084  
Poland

Holds Certificate Number:

KM 712847


In respect of:

**BS EN 50171**  
**Central power supply systems**

This issues the right and licence to use the Kitemark in accordance with the Kitemark Terms and Conditions governing the use of the Kitemark, as may be updated from time to time by BSI Assurance UK Ltd (the "Conditions"). All defined terms in this Certificate shall have the same meaning as in the Conditions.

The use of the Kitemark is authorized in respect of the Product(s) detailed on this Certificate provided at or from the above address.

For and on behalf of BSI:



Chris Lewis - Certification Director, Product Certification

First Issued: 2019-08-08

Latest Issue: 2019-08-08

Effective Date: 2019-08-08

Expiry Date: 2022-08-07



Page: 1 of 4

...making excellence a habit.™

# Kitemark™ Certificate

No. KM 712847

## Central Power Supply Systems – BS EN 50171:2001 and BS EN 50272:2001

BSI Test Report Number 9787874

Rated: 230V AC, 50Hz, Cl.I, Uout - 216V DC, IP20

Model	Power (1hr)	Power (2hrs)	Power (3hrs)	Number of circuits	Number of fittings	Control panel	Closed housing
00710M	900W	650W	400W	10	200	NO	-
00710MP	900W	650W	400W	10	200	YES	-
00724M	900W	650W	400W	24	480	NO	-
00724MP	900W	650W	400W	24	480	YES	-
01210M	1560W	1110W	650W	10	200	NO	-
01210MP	1560W	1110W	650W	10	200	YES	-
01224M	1560W	1110W	650W	24	480	NO	-
01224MP	1560W	1110W	650W	24	480	YES	-
01810M	2330W	1670W	970W	10	200	NO	-
01810MP	2330W	1670W	970W	10	200	YES	-
01824M	2330W	1670W	970W	24	480	NO	-
01824MP	2330W	1670W	970W	24	480	YES	-
00710	900W	650W	400W	10	200	NO	S1
00710P	900W	650W	400W	10	200	YES	S1
00724	900W	650W	400W	24	480	NO	S1
00724P	900W	650W	400W	24	480	YES	S1
01210	1560W	1110W	650W	10	200	NO	S1
01210P	1560W	1110W	650W	10	200	YES	S1
01224	1560W	1110W	650W	24	480	NO	S2
01224P	1560W	1110W	650W	24	480	YES	S2
01810	2330W	1670W	970W	10	200	NO	S2

First Issued: 2019-08-08

Latest Issue: 2019-08-08

Effective Date: 2019-08-08

Expiry Date: 2022-08-07

Page: 2 of 4

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

# Kitemark™ Certificate

No. KM 712847

## Central Power Supply Systems – BS EN 50171:2001 and BS EN 50272:2001

BSI Test Report Number 9787874

Rated: 230V AC, 50Hz, Cl.I, Uout - 216V DC, IP20

Model	Power (1hr)	Power (2 hrs)	Power (3hrs)	Number of circuits	Number of fittings	Control panel	Closed housing
01810P	2330W	1670W	970W	10	200	YES	S2
01824	2330W	1670W	970W	24	480	NO	S3
01824P	2330W	1670W	970W	24	480	YES	S3
02610	3370W	2410W	1400W	10	200	NO	S3
02610P	3370W	2410W	1400W	10	200	YES	S3
02624	3370W	2410W	1400W	24	480	NO	S3
02624P	3370W	2410W	1400W	24	480	YES	S3
03310	4280W	3060W	1780W	10	200	NO	S3
03310P	4280W	3060W	1780W	10	200	YES	S3
03324	4280W	3060W	1780W	24	480	NO	S3
03324P	4280W	3060W	1780W	24	480	YES	S3

### Legend:

M – no housing

P – control panel installed

Dimensions of the system cabinet:

Cabinet type	S1	S2	S3
Dimension [mm]	1205 x 501 x 307	1250 x 600 x 398	1550 x 646 x 487

First Issued: 2019-08-08

Latest Issue: 2019-08-08

Effective Date: 2019-08-08

Expiry Date: 2022-08-07

Page: 3 of 4

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.  
A member of BSI Group of Companies.

# Kitemark™ Certificate

No. KM 712847

## Central Power Supply Systems – BS EN 50171:2001 and BS EN 50272:2001

BSI Test Report Number 9787874

The TM-CB A is a central battery system used for emergency lighting. The TM-CB A is a modular system with model 03324P being tested as a representative of the range.

The TM-CB A central battery systems allows the connection of fluorescent, halogen and LED fittings, depending on the type of modules used.

The TM-CB A is constructed in a metal class I grey powder coated enclosure, which is vented, lockable and incorporates a digital monitoring display on the front panel/door.

First Issued: 2019-08-08

Latest Issue: 2019-08-08

Effective Date: 2019-08-08

Expiry Date: 2022-08-07

Page: 4 of 4

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.  
A member of BSI Group of Companies.